

FITNESS CERTIFICATE

TO BE FILLED BY THE INSPECTING OFFICER

(ASSISTANT ENGINEER)

- 1 Name of the Officer : SUBIN SEKHAR
- 2 Name of the School : Saraswathy Vidhya Nikethan Central School Perambra
Kodakara
- 3 Location with Name of Educational
District Sub District : Chalakudy Sub Dist. Irinjalakuda Dist.
- 4 Classification buildings as specified in Col. 4 : Main Block
Of the application for fitness certificate & Size : 600*600(6- class rooms) GF
: 600*600 (1- Staff room, 1- Director Board room)
: 600*600 (6- class rooms) FF
: 600*600 (Staff room, Computer Lab-FF)
: 1456*600 (Library)
: 600*600 (7- Class room) SF
: 600*600 (3- No Labs-SF)
Main Block Total Area = 2602 M2
Vivekanadha Block
: 600*600 (8- class rooms)
: 440*600 (Staff room-GF, FF & SF)
Total Area- 1635.30 M2
- 5 Period For which the certificate is issued : 2022-23
- 6 Nature of Defect if any
- | | |
|------------------------------|------------------|
| cc) Foundation and Basement | : Good Condition |
| dd) Super Structure | : Good Condition |
| ee) Doors and Windows | : Good Condition |
| ff) Wood Work Wrought put up | : Nil. |

gg) Roof : Good Condition
hh) Flooring : Good Condition
ii) Miscellaneous cracks etc : Cracks on two classes

7 Any major defects noticed which will render
The building unsafe in any manner : No

8 Whether the maintenance works have been
Done properly : Yes

9 Whether structure is safe for conducting classes : Sound under normal weather conditions.

Note : Advice to carry out water proofing works to avoid the dampness in the roof slab.
Stair Room to be locked

CERTIFICATE

Certified that the school building was inspected by me on **25-05-2022** and found to be fit/unfit to conduct classes, for the period **2022-2023** for the reasons stated

Place : Kodakara

Date : 28-05-2022

(Seal)



Assistant Engineer

SUBIN SEKHAR
ASSISTANT ENGINEER
L.S.G.D.

Kodakara Section

Date:

PRINCIPAL
SARASWATHY VIDYANIKETHAN
CENTRAL SCHOOL
KODAKARA, PERAMBRA.P.O.



MANAGER
SARASWATHY VIDYANIKETHAN
CENTRAL SCHOOL
KODAKARA, PERAMBRA.P.O.