

FITNESS CERTIFICATE

TO BE FILLED BY THE INSPECTING OFFICER

(ASSISTANT ENGINEER)


- 1 Name of the Officer : ANJU KUNJUMON
- 2 Name of the School : Saraswathy Vidhya Nikethan Central School Perambra
,Kodakara
- 3 Location with Name of Educational
District Sub District : Chalakudy Sub Dist. Irinjalakuda Dist.
- 4 Classification buildings as specified in Col. 4 : **Main Block**
Of the application for fitness certificate & Size : 600*600(6- class rooms) GF
: 600*600 (1- Staff room, 1- Director Board room)
: 600*600 (6- class rooms) FF
: 600*600 (Staff room, Computer Lab-FF)
: 1456*600 (Library)
: 600*600 (7- Class room) SF
: 600*600 (3- No Labs-SF)
Main Block Total Area = 2602 M2
Vivekanadha Block
: 600*600 (8- class rooms)
: 440*600 (Staff room-GF, FF & SF)
Total Area- 1635.30 M2
- 5 Period For which the certificate is issued : 2026-27

6 Nature of Defect if any

- a) Foundation and Basement : Good Condition
b) Super Structure : Good Condition
c) Doors and Windows : Good Condition
d) Wood Work Wrought put up : Nil.



MANAGER
SARASWATHY VIDYANIKETHAN
CENTRAL SCHOOL



SARASWATHY VIDYANIKETHAN
CENTRAL SCHOOL
KODAKARA, PERAMBRA P.C.

- e) Roof : Good Condition
f) Flooring : Good Condition
g) Miscellaneous cracks etc : Cracks on two classes

7 Any major defects noticed which will render
The building unsafe in any manner : No

8 Whether the maintenance works have been
Done properly : Yes

9 Whether structure is safe for conducting classes : Sound fit under normal wind and weather conditions.

Note : Advice to carry out water proofing works to avoid the dampness in the roof slab.
Stair Room to be locked.

CERTIFICATE

Certified that the school building was inspected by me on 24-06-2025 and found to be fit/unfit to conduct classes, for the period 2026-27 for the reasons stated.


Building is structurally stable and clearance from health dept. is obtained. Hence the structure is deemed fit from this perspective. However, vide order no. GEPN-MI/188/2025 - GEPN - dated 13.05.2026, H.M should ensure fitness check from Electrical Inspectorate, Fire and Rescue Dept., Forest and Wild Life Dept., Motor Vehicle Dept. within the stipulated period.

Place : Kodakara
Date : 25-06-2026

(Seal)



Assistant Engineer



ASSISTANT ENGINEER
L.S.G.D.
Kodakara Section
Date:

MANA
SARASWATHY VIDYANIKETHAN
CENTRAL SCHOOL
KODAKARA PERAMBRA P.O.

PRINCIPAL
SARASWATHY VIDYANIKETHAN
CENTRAL SCHOOL
PERAMBRA P.O.